

AD A 054767

TECHNICAL REPORT CIVIL ENGINEERING LABORATORY

Naval Construction Battalion Center, Port Hueneme, California 93043

OC FILE COP

OPERATING COST EVALUATION OF SULFUR DIOXIDE REMOVAL SYSTEMS FOR BOILER APPLICATIONS

By John M. Slaminski

April 1978

Sponsored by

NAVAL MATERIAL COMMAND

Approved for public release; distribution unlimited.



Unclassified SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered) READ INSTRUCTIONS BEFORE COMPLETING FORM REPORT DOCUMENTATION PAGE 2. GOVT ACCESSION NO. RECIPIENT'S CATALOG NUMBER TR-864/ DN687069 OPERATING COST EVALUATION OF SULFUR Jan 1977 - Sep 1977 DIOXIDE REMOVAL SYSTEMS FOR BOILER APPLICATIONS. CONTRACT OR GRANT NUMBER(s) John M. Slaminski PERFORMING ORGANIZATION NAME AND ADDRESS CIVIL ENGINEERING LABORATORY Naval Construction Battalion Center ZF57/571/00101.015 Port Hueneme, California 93043 . CONTROLLING OFFICE NAME AND ADDRESS April 1978 Chief of Naval Material Command Navy Department 44 20360
CY NAME & ADDRESS(II different from Controlling Office) 15. SECURITY CLASS. (of this report) Unclassified 15a. DECLASSIFICATION DOWNGRADING 16. DISTRIBUTION STATEMENT (of this Report) Approved for public release; distribution unlimited. 17. DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different from Report) 18. SUPPLEMENTARY NOTES 19. KEY WORDS (Continue on reverse side if necessary and identify by block number) Steam generating plant, sulfur dioxide, lime slurry scrubbing, boilers, double alkali, sulfuric acid. ABSTRACT (Continue on reverse side if necessary and identify by block number) Seven commercial processes for extracting sulfur dioxide from steam or steam-electric generating plants are analytically compared. The operation and economics of lime and limestone slurry scrubbing, dilute and concentrated double alkali, and dilute sulfuric acid processes with gypsum disposal products are contrasted with sodium sulfite/bisulfite and activated char sulfur recovery systems. Each process is critically analyzed to yield system flows and operating expenses (including equipment power consumption, product disposal DD 1 JAN 73 1473 EDITION OF 1 NOV 65 IS OBSOLETE

in 391 111

Unclassified
SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

AB

SECURITY CLASSIFICATION OF THIS PAGE(When Date Entered)

20. Continued

Acosts or credits, reagent requirements and operating and maintenance costs). The laws for scaling these results to any given plant capacity and coal sulfur content are developed and parametrically graphed. This information is a valuable guide for the Navy or utility engineer to perform accurate system evaluations.

Library Card

Civil Engineering Laboratory
OPERATING COST EVALUATION OF SULFUR DIOXIDE
REMOVAL SYSTEMS FOR BOILER APPLICATIONS, by
John M. Slaminski

TR-864

44 pp illus

April 1978

Unclassified

1. Sulfur dioxide extraction

2. Generating plants

I. ZF57.571.001.01.015


Seven commercial processes for extracting sulfur dioxide from steam or steam-electric generating plants are analytically compared. The operation and economics of lime and limestone slurry scrubbing, dilute and concentrated double alkali, and dilute sulfuric acid processes with gypsum disposal products are contrasted with sodium sulfite/bisulfite and activated char sulfur recovery systems. Each process is critically analyzed to yield system flows and operating expenses (including equipment power consumption, product disposal costs or credits, reagent requirements and operating and maintenance costs). The laws for scaling these results to any given plant capacity and coal sulfur content are developed and parametrically graphed. This information is a valuable guide for the Navy or utility engineer to perform accurate system evaluations.

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE(When Date Entered)

CONTENTS

	Page
INTRODUCTION	1
BASES FOR COMPARISONS	1
Exhaust Gas Flow Characteristics	
Fan and Pump Power Requirements	6
Process Flow Calculations	14
Energy and Reagent Unit Costs	18
Economics	
neonomics	-
SYSTEMS STUDIED	20
Lime Slurry System	20
Limestone Slurry System	
Dilute Acid System	
Dilute Double Alkali	200
Concentrated Double Alkali	
Sodium Sulfite/Bisulfite Process	
Activated Char Adsorption System	. 30
SUMMARY	. 32
REFERENCES	. 34
ACKNOWLEDGMENT	. 34
NOMENCLATURE	. 35
ABBREVIATIONS	. 37



INTRODUCTION

The Navy currently operates more than 2,000 boilers to provide space heating and process steam for shore facilities. Many of these boilers are obsolete and inefficient, which has led many Navy field activities to consolidate distributed boilers into modern centralized boiler plants. The Navy has been directed to utilize coal in new boiler facilities by the issuance of OPNAVINST 4100.6. Many of the larger Navy boiler plants will be subject to Federal, state, and local emission

control regulations, including the removal of sulfur dioxide.

Seven commercial processes for extracting sulfur dioxide from steam or steam-electric generating plants are analytically compared. The operation and economics of lime and limestone slurry scrubbing, dilute and concentrated double alkali, and dilute sulfuric acid processes with gypsum disposal products are contrasted with sodium sulfite/bisulfite and activated char sulfur recovery systems. Each process is critically analyzed to yield system flows and operating expenses (including equipment power consumption, product disposal costs or credits, reagent requirements, and operating and maintenance costs). The laws for scaling these results to any given plant capacity and coal sulfur content are developed and parametrically graphed. This information is a valuable guide for the Navy or utility engineer to perform accurate system evaluations with ease.

BASES FOR COMPARISON

Exhaust Gas Flow Characteristics

Exhaust gas volumetric flow rates from the steam generator are plotted in Figure 1 for conditions at the booster fan discharge prior to entering the absorber or prescrubber, as well as at the absorber exit saturated in water vapor. The predictions are based on combustion calculations described in detail in a previous publication (1) and experimentally verified shortly thereafter (2). The procedure is somewhat lengthy and is beyond the scope of this paper. The predicted flue gas flows correspond to these conditions:

Unit Net Heat Rate

10,546 kJ/kWh (10,000 Btu/kWh)

Air Preheater Volumetric Leakage 10% incoming flow




Figure 1. Steam generator exhaust gas volumetric flow rate. (Multiply flows by 10 for 500 MW capacity.)

Prescrubber/Absorber Inlet:

Gas Temperature 121C (250F)
Gas Pressure 10.6 Nsca (15.4 psia)
Moisture Content 10% (molar)

Absorber Exit:

Gas Temperature 52C (125F)
Gas Pressure 10.1 Nsca (14.7 psia)
Moisture Content 15% (molar)

The exhaust gas temperature and moisture content were obtained by an iterative solution of the adiabatic humidification, illustrated in the diagram and given in the equation

$$T_{1} - T_{2} = \frac{m_{w2} - (h_{w2} - h_{w}) + m_{w1}(h_{w} - h_{w1})}{C_{pg}/\eta_{H}}$$
(1)

where

$$m_w = m_{w1} - m_{w2}$$

Coal and untreated SO₂ flow rates can easily be computed from

$$\dot{w}_{SO_2} = F_S \dot{w}_F = \frac{HR_N G F_S}{30 \text{ HHV}} (kg/min; 1b/min)$$
 (2)

and were plotted in Figure 2. The removal efficiency of the SO₂ process necessary to meet the Environmental Protection Agency (EPA) standard of performance is shown in Figure 3, indicating that a 90% design efficiency would satisfy this regulation for nearly all coal supplies. The heat rate and coal heating value used throughout this paper are:

Unit Net Heat Rate 10,546 kJ/kWh (10,000 Btu/kWh)

Fuel Higher Heating Value 23,250 kJ/kg (10,000 Btu/lb)




Figure 2. Untreated sulfur dioxide flow rate. (Multiply flows by 10 for 500 MW capacity.)




Figure 3. Design sulfur dioxide removal efficiency relative to EPA emission regulation for new units.

Fan and Pump Power Requirements

The fan power equation is derived from energy considerations applied to the gas flow on both sides of the fan to yield:

$$P_{W} = 1.173 \times 10^{-4} \frac{\dot{v}_{g} \Delta P_{g}}{\eta_{F}} \qquad \frac{P_{w}}{kW} \frac{\dot{v}_{g}}{acfm} \frac{\Delta P_{g}}{in. \text{ wwc}}$$

$$P_{w} = 1.573 \times 10^{-4} \frac{\dot{v}_{g} \Delta P_{g}}{\eta_{F}} \qquad \text{hp} \qquad acfm \qquad in. \text{ wwc} \qquad (3)$$

$$P_{w} = 1.640 \times 10^{-3} \frac{\dot{v}_{g} \Delta P_{g}}{\eta_{F}} \qquad kW \qquad acmm \qquad cm \text{ wwc}$$

Fan power relative to the SO₂ system flue gas pressure loss is plotted

in Figures 4 and 5.

Typical gas pressure losses through system components are listed and were utilized to arrive at fan power requirements for the following SO, processes:

Components	cm vwc	in. vwc
Venturi Prescrubber	13	5
Spray Tower	10	4
Fixed Bed Absorber	30	12
Mobile Bed Absorber	30	12
Activated Char Absorber	46	18
Mist Eliminator	3	1

A fan efficiency of 75% was used when applying Equation 3 to the candidate SO, systems.

A similar analysis leads to the pump power relationship for process

liquor flows.




Figure 4. Fan power in metric units required to drive exhaust gas through SO₂ system. (Multiply power by 10 for 500 MW² capacity.)




Figure 5. Fan power required to drive exhaust gas through SO₂ system. (Multiply power by 10 for 500 MW capacity.)

$$P_{W} = 4.35 \times 10^{-4} \frac{\dot{W}_{L} \Delta P_{L}}{\eta_{p}}$$

$$P_{W} = 5.83 \times 10^{-4} \frac{\dot{W}_{L} \Delta P_{L}}{\eta_{p}}$$

$$kW gpm psi$$

$$hp gpm psi (4)$$

$$P_{W} = 1.67 \times 10^{-4} \frac{\dot{W}_{L} \Delta P_{L}}{\eta_{p}}$$

$$kW lpm nsc$$

Parametric graphs of relative pump power requirements are shown in Figures 6 and 7 for convenient analyses. A pump efficiency of 60% is typical for slurry flows; 75% is more representative of clear liquor flows. These flows were adopted to arrive at pump power for the candidate processes analyzed.

The relationship for prediction of liquor flow pressure losses in piping systems is considerably more variable than the flue gas situation.

$$\Delta P_{L} = \rho_{L} H + f \frac{L}{d} \frac{\rho_{L} V_{L}^{2}}{2g_{0}} + K_{A} \frac{\rho_{L} V_{L}^{2}}{2g_{0}} + \Delta P_{sn} + \Delta P_{cv}$$
 (5)

$$\Delta P_{CV} = \frac{F_M^2 - 1}{F_M^2} \Delta P_L$$
 (6)

The control valve relationship is a function of the flow margin desired over nominal design conditions F_M . All terms but the pressure loss due to pumping to higher elevations $(\rho_L H)$ are a function of dynamic pressure drop $(\rho_L V_L^{-2}/2g_0)$. Figure 8 contains the dynamic pressure drop variation with liquor velocity, and elevation pressure losses appear in Figure 9.

The following conditions were set for determining piping system pressure losses for each of the candidate processes:




Figure 6. Liquid pump power requirements in metric units. (Multiply power by 10 for 500 MW capacity.)




Figure 7. Liquid pump power requirements. (Multiply power by 10 for 500 MW capacity.)




Figure 8. Static pressure drop required to generate indicated liquid velocity.




Figure 9. Pressure loss due to pumping liquor to higher elevations.

Conditions

Liquor Velocity	3 m/s (10 fps)
10% Solids Slurry Specific Gravity	1.13
40% Solids Slurry Specific Gravity	2.00
Specific Gravity Soluble Salts in	
Clear Liquor	1.12
Specific Gravity Low Solubility Salts in	
Clear Liquor	1.00
Prescrubber or Absorber Height	24 m (80 ft)
Absorber Piping System Length	30 m (100 ft)
Liquor Transfer System Tank Height	6 m (20 ft)
Liquor Transfer Piping System Length	30 m (100 ft)
Absorber Recycle Flow Margin	0%
Liquor Transfer System Flow Margin	25%
Sum of Minor Loss Coefficients	10
Absorber Slurry Spray Nozzle Pressure Loss	14 nsc (20 psi)
Absorber Clear Liquor Header Loss	3 nsc (5 psi)

These yielded the following system pressure losses:

Systems	nsc	psi
Slurry Spray Absorber Recycle	57	83
Clear Liquor Absorber Recycle	41	60
10% Solids Liquor Transfer System	23	34
40% Solids Liquor Transfer System	46	66
Clear Liquor Transfer System	21	30

With few exceptions, these piping system pressure losses were generally utilized for each of the candidate systems.

Process Flow Calculations

The mass flow rate demand by the absorber for any particular reagent to react with SO $_2$ is given by a relation involving the stoichiometric coefficients $(\vee)^2$ of the chemical reactions.

$$\dot{\mathbf{w}}_{R} = \sum_{1}^{P} \frac{\mathbf{v}_{R}^{M} \mathbf{w}_{R}}{\mathbf{v}_{SO_{2}}^{M} \mathbf{w}_{SO_{2}}} \frac{\mathbf{F}_{RP} \dot{\mathbf{w}}_{SO_{2}}}{\mathbf{F}_{URP}}$$
(7)

Similarly, the mass flow of any one product generated in the absorber is available from the following relationship

$$\dot{\mathbf{w}}_{\mathbf{P}} = \sum_{1}^{\mathbf{R}} \frac{\mathbf{v}_{\mathbf{P}}^{\mathbf{M}} \mathbf{w}_{\mathbf{P}}}{\mathbf{v}_{\mathbf{R}}^{\mathbf{M}} \mathbf{w}_{\mathbf{R}}} \mathbf{F}_{\mathbf{RP}} \mathbf{F}_{\mathbf{URP}} \dot{\mathbf{w}}_{\mathbf{R}}$$
(8)

where the reagent is consumed by the reaction with SO₂ in Equation 7. Slurried liquor flow rates required for absorber bleed streams to remove product salts as they are generated in the recycle loop can be calculated from known product and reagent mass flows.

$$\dot{\mathbf{w}}_{L} = \frac{\sum_{1}^{P} \dot{\mathbf{w}}_{P} + \sum_{1}^{R} \sum_{1}^{P} (1 - F_{URP}) F_{RP} \dot{\mathbf{w}}_{R}}{F_{SS} \rho_{w}}$$

Equation 9 was used to calculate all thickener underflows as well as absorber bleed and return slurries. In this analysis, thickener performance was fixed at 40% solids in the underflow, and vacuum filter cake was assumed to be 70% solids. A slightly modified version is used to calculate lime or limestone preparation slurries.

$$\dot{\mathbf{w}}_{L} = \frac{\sum_{1}^{R} \dot{\mathbf{w}}_{R}}{\mathbf{F}_{SS} \rho_{w} + \sum_{1}^{1} \sum_{1}^{R} \mathbf{s}_{R}}$$
(10)

If the product is completely dissolved, the liquor flow relationship takes on a different form.

$$\dot{\mathbf{w}}_{\mathbf{L}} = \frac{\dot{\mathbf{w}}_{\mathbf{P}}}{\mathbf{X}_{\mathbf{p}} \mathbf{F}_{\mathbf{R}\mathbf{G}}} \tag{11}$$

The product requiring the greatest liquor flow rate is the controlling factor in setting the necessary liquor flow. Product concentrations were usually held near the solubility limit (S_R) to minimize liquor flow rates.

The listing or deriving of equations for crystalizer steam requirements, sand heater fuel flow, exhaust gas reheat fuel demand, condenser or char cooler water flow rates, or heated sand recirculation rates are omitted for brevity. These calculations are usually accomplished by a simple heat balance, and results are included in Table 1, along with all the other process flow rates. Space considerations have limited the number of process liquor flows to the major ones shown in Table 1, although all flows indicated on the process diagrams were determined and included in these analyses.

continued

Table 1. System Operating Parameters at Full Load (500-MW and 1% sulfur fuel)

Item	Type of Units	Lime Slurry	Limestone Slurry	Dilute Acid	Dilute Double Alkali	Concentrated Double Alkali	Sodium Sulfite/ Bisulfite	Activated Charcoal
Exhaust Gas Flow Rate	acmm	38,953	38,953 1,376,430	38,953	38,953	38,953 1,376,430	38,953 1,376,430	43,257 1,528,500
SO ₂ Flow Rate	kg/min Ib/min	76 167	76 167	76 167	76 167	76 167	76 167	76 167
Fan Power	kW	2,505	2,505	4,418 5,924	4,418 5,924	4,418 5,924	4,418 5,924	4,423 5,930
Pump Power	kW hp	5,028 6,742	5,028 6,742	2,215 2,966	2,252 3,016	2,093	3,704	99
Reheat/Sand Heater Oil	l/min gpm	35.6	35.6	35.6	35.6	35.6	35.6	11.4
Process Steam Flow	kg/min lb/min	1 1	l I	1 1	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	 	716 1,579	1 1 2d 7 dij
Prescrubber Recycle Flow	l/min gpm	1-1	11	78,122 20,640	78,122 20,640	78,122 20,640	78,122 20,640	11
Absorber Recycle Flow	l/min gpm	312,490 82,560	312,490 82,560	145,830 38,528	145,830 38,528	145,830 38,528	145,830 38,528	1 (5 m)
Absorber Bleed Rate	l/min gpm	2,263 (10%S) 598 (10%S)	2,369 (10%S) 626 (10%S)	11,620	19,667 5,196	2,347 620	1,480	985 (kg/min) 2,171 (lb/min)
Reagent Flow	kg/min Ib/min	89 196 CaO	158 348 CaCO ₃	121 266 CaCO ₃	68 149 CaO	74 163 CaO	0.5 1 CaO	96 211 maximum char
(Natural Gas — scmm) (Natural Gas — scfm)	kg/min Ib/min	19 42 stabilizer	19 42 stabilizer	20 45 stabilizer	20 45 stabilizer	20 45 stabilizer	40 1,425 natural gas	40 1,425 natural gas
	kg/min Ib/min	I, I I,	1 1 1 51 2 1 6260	0.5 ~1 Fe ₂ (SO ₄) ₃	14 31 Na ₂ CO ₃	14 36 Na ₂ CO ₃	12 26 Na ₂ CO ₃	13 29 minimum char

Table 1. Continued

			-	_	_	
Activated Charcoal	38	83	S	1	1	-
Sodium Sulfite/ Bisulfite	38	83	s	35	78	Na salt cake
Concentrated Double Alkali	15	34	CaSO ₄ 2H ₂ O	188	415	CaSO ₃ 2H ₂ O
Dilute Concentrated Double Alkali Double Alkali	204	449	CaSO ₄ 2H ₂ O CaSO ₄ 2H ₂ O CaSO ₄ 2H ₂ O	2	4	Ca(OH)2
Dilute Acid	203	448	CaSO ₄ 2H ₂ O	2		CaCO ₃
Limestone Slurry	82	180**	CaSO ₄ 2H ₂ O	111	244.	CaSO ₃ 2H ₂ O
Lime Slurry	82	180	CaSO ₄ 2H ₂ O	1111	244	CaSO ₃ 2H ₂ O
Type of Units	kg/min	lb/min		kg/min	lb/min	
Item	Product Solids					

Note: 1. To adjust all flows to new plant capacities, multiply by new MW/500.

2. To adjust all flows to new fuel sulfur contents, multiply by new fuel 5%/1% (exception-exhaust gas flow is not a function of sulfur content).

*Plus 65 lb Unreacted Ca(OH)2

** Plus 87 lb Unreacted CaCO3

Energy and Reagent Unit Costs

Units

Electrical Power Delivered Coal Natural Gas Steam Cost Distillate Fuel Oil 90% Lime Delivered 85% Limestone Delivered Filter Cake Stabilizer Soda Ash Delivered Fe(OH), Delivered Activated Char Disposal Cost Sulfur Credit Capital Cost SO₂ System Capital Cost of Steam Electric Unit Sodium Salt Cake Credit Maintenance Costs Operating Labor Cost

Costs

20 mills/kWh \$0.49/GJ (\$0.52/MBtu) \$1.61/GJ (\$1.70/MBtu) \$2.15/GJ (\$2.27/MBtu) \$2.63/GJ (\$2.77/MBtu) \$51/M ton (\$46/ton) \$34/M ton (\$31/ton) \$56/M ton (\$51/ton) \$80/M ton (\$73/ton) \$133/M ton (\$121/ton) \$286/M ton (\$260/ton) \$0.66/M ton (\$0.60/ton) \$24/M ton (\$22/ton) \$150/kW

\$350/kW \$11/M ton (\$10/ton) 2% Capital Investment/Yr \$15/hr

Economics

The basic operating cost relationships are quite simple to derive and easy to use.

$$C_{o} = U \dot{W} t L_{c} \qquad \$/yr \qquad (12)$$

$$c_o = \frac{U W^{\bullet}(10^3)}{G} \quad mills/kWh$$
 (13)

$$C_o = \frac{10^6 \text{ U } \dot{\text{W}}}{\text{HR}_N \text{ G}} \qquad \text{$/\text{MBtu}}$$
 (14)

Process economics are tabulated in Table 2 for each candidate SO_2 removal system.

Table 2. System Operating Costs at Full Load (1% sulfur fuel)

Cost Items	Type of Units	Lime Slurry	Limestone Slurry	Dilute Acid	Dilute Double Alkali	Concentrated Double Alkali	Sodium Sulfite/ Bisulfite	Activated Charcoal
Fan Power Cost	mills/kWh	0.1002	0.1002	0.1770	0.1770	0.1770	0.1770	0.1768
Pump Power Cost	mills/kWh	0.2000	0.2000	0.0890	0.0901	0.0837	0.1100	0.0026
Reheat Fuel Oil	mills/kWh	0.4319	0.4319	0.4319	0.4319	0.4319	0.4319	1
Sand Heater Fuel Oil	mills/kWh	1	1	-	1		1	0.1370
Process Steam Cost	mills/kWh	1	1	1	1	1	0.397	1
Reagent Cost	mills/kWh	0.6010 CaO	0.7490 CaCO ₃	0.5730 CaCO3	0.4570 CaO	0.5000 CaO	0.0030 CaO	3.290* maximum char
	mills/kWh	0.1290 stabilizer	0.1290 stabilizer	0.1380 stabilizer	0.1380 stabilizer	0.1380 stabilizer	0.2975 natural gas	0.2910 natural gas
	mills/kWh	1 1	1 1	0.0035 Fc ₂ (OH) ₃	0.1350 Na ₂ CO ₃	0.1580 Na ₂ CO ₃	0.1140 Na ₂ CO ₃	0.4520 minimum char
Disposal Costs (credits)	mills/kWh	0.0306 filter cake	0.0312 filter cake	0.0283 filter cake	0.0298 filter cake	0.0301 filter cake	(0.1100) S	(0.1100) S
	mills/kWh	1 1	1 1	1 1	1 1	2 - B	(0.0500) salt cake	0.0076 waste char
Operating Labor Cost Maintenance Cost	mills/kWh mills/kWh	0.1160	0.1160	0.1160	0.1160	0.1160	0.1160	0.1160 0.4200
Total Costs	mills/kWh	2.0287	2.1773	1.9767	1.9948	2.0547	1.9064	4.3310*
	10 ⁶ \$/yr	7.1086	7.6293	6.9264	8686.9	7.1997	0089.9	15.1760* -5.2315

Note: 1. To adjust all costs to new fuel sulfur content, multiply by new fuel S%/1% (except fan power costs are not a function of fuel sulfur content).

2. Total costs in 10⁶ \$/yr corresponds to a \$00-MW unit capacity.

3. To convert costs from mills/kWh to \$/MBtu, multiply by 0.10.

*Maximum char loss values.

SYSTEMS STUDIED

Lime Slurry System

The chemistry of lime slurry scrubbing is straight forward with $CaSO_4$ and $CaSO_3$ produced in the absorber on reacting with SO_2 . The lime forms $Ca(OH)_2$ when contacted with water.

Ca0 +
$$H_2^0 \rightarrow Ca(OH)_2$$

Absorber

 $Ca(OH)_2 + SO_2 \rightarrow CaSO_3 + H_2^0$
 $2Ca(OH)_2 + 2SO_2 + O_2 \rightarrow CaSO_4 + 2H_2^0$

Approximately 40% of the SO₂ reacts to form CaSO₄ and 60% forms CaSO₃ (3). A great deal of variability in lime utilization ($F_{\rm URP}$) in slurry systems is reported in the literature, ranging from 50% to 100%. The fact that slurry scrubbing relies on suspended lime particles as the reacting media renders high utilization values doubtful. A lime utilization of 75% was selected for this comparison.

The process diagram in Figure 10 shows a closed loop operation, which conserves water and reduces the size of the disposal pond. Extensive scale buildup in the absorber internals and sump area has plagued the lime slurry systems over the history of their operation, particularly during closed loop operation. A precipitator ahead of the absorber is recommended to reduce the solids level in the absorber slurry, and an open spray tower absorber design is a necessity to prevent plugging of the gas flow and liquor flow paths. Basically, scale buildup will always be a problem with slurry systems, since the return liquor to the absorber is saturated in CaSO₃ and CaSO₄ and becomes supersaturated in the absorber when the Ca(OH)₂ is converted to CaSO₃ or CaSO₄.

The system advantage is that operation is relatively simple due to the small number of components.

System disadvantages include:

- Scale buildup causes high maintenance even with an open spray tower absorber.
- 2. Mist eliminator scaling and plugging are continuous maintenance items.
- 3. Particulate emission performance is well below that of clear liquor processes, due to entrained solids.
- Large quantities of lime and gypsum movement in and out of the plant area conflict with power plant operation.
- Water pollution is a problem of the CaSO₃ product, as are CaSO₃ crystal growth difficulties in the thickener.




Figure 10. Lime or limestone slurry SO_2 removal system.

Limestone Slurry System

The process flow diagram for limestone slurry scrubbing is identical to that for lime slurry systems (Figure 10). The chemistry is also similar.

Absorber
$$CaCO_3 + SO_2 \rightarrow CaSO_3 + CO_2$$

 $2CaCO_3 + 2SO_2 + O_2 \rightarrow 2CaSO_4 + 2CO_2$

The comments delineated for lime slurry scrubbing apply to limestone.

Dilute Acid System

The flow diagram for this system is shown in Figure 11, and the chemistry is quite simple.

Absorber
$$SO_2 + H_2O \rightarrow H_2SO_3$$

$$2H_2SO_3 + O_2 \rightarrow 2H_2SO_4$$
 Oxidizer
$$2H_2SO_3 + O_2 \rightarrow 2H_2SO_4 \quad \text{(To completion)}$$
 Reactor Thickener
$$CaCO_3 + H_2SO_4 \rightarrow CaSO_4 + CO_2 + H_2O$$

The acid bleed from the absorber is reportedly (4) 2% by weight, which corresponds to a pH of 0.4 if the acid is 100% ionized (or about 1 to 2 if partially ionized). The acid is partially neutralized to a 1% acid solution by weight in the reactor thickener. Partial neutralization of the acid results in an extremely low calcium sulfate concentration, that is unsaturated in the absorber due to make-up water addition and a favorable temperature solubility behavior for CaSO₄. Limestone utilizations are about 98%.

System advantages are:

- 1. Scale buildup in the absorber and mist eliminator are eliminated.
- 2. Limestone utilization is excellent.
- Almost pure CaSO₄ is produced.
- 4. Particulate removal performance is good.

System disadvantages include:




Figure 11. Dilute acide SO_2 removal system.

Single Component Solution

Complex Solution

Na ₂ SO ₄	1.37 moles/l	Na SO	1.16 moles/1
Ca(OH)	0.022	Ca(OH)	
CaSO	0.0151	CaSO	0.0002
NaOH	27.3	NaOH	0.12 (equilibrium)

The design concentration for Na_2SO_4 is appropriately 1 molar, but the liquor bleed rate from the absorber is still determined by the fact that only 0.06 moles/1 - or 6% - of the incoming Na_2SO_4 can be regenerated in the reaction tank.

Process advantages include:

- 1. Scale buildup in the absorber and mist eliminator is eliminated.
- 2. Lime utilization is excellent.
- 3. Almost pure CaSO, is produced for ease in filtering and disposal.
- 4. Good particulate removal performance is noted.

Process disadvantages include:

- Large liquor bleed rates result in relatively large thickener, clarifier, and surge vessels.
- Slightly higher pump costs are noted with this process than with some processes.
- 3. Large amounts of material movement in and out of the plant area interfere with operations.

Concentrated Double Alkali

The process flow diagram for the concentrated operating mode of the double alkali process is also shown in Figure 12, but the regeneration chemistry is much more favorable than the dilute operational mode.

Absorber
$$NaOH + SO_2 \rightarrow NaHSO_3$$

 $Na_2SO_3 + SO_2 + H_2O \rightarrow 2NaHSO_3$
 $4NaOH + 2SO_2 + O_2 \rightarrow 2Na_2SO_4 + 2H_2O$
Reaction Tank $Ca(OH)_2 + 2NaHSO_3 \rightarrow Na_2SO_3 + CaSO_3 + 2H_2O$
 $Ca(OH)_2 + Na_2SO_3 \rightarrow 2NaOH + CaSO_3 + Ca(OH)_2 + Na_2SO_4 \rightarrow 2NaOH + CaSO_4 + CaSO_$




Figure 12. Double alkali SO₂ removal system, dilute and concentrated modes.

The primary reactions for the removal of SO₂ from the exhaust gas are the formation of NaHSO₃ from NaOH and Na₂SO₃. The scrubbing solution bled from the absorber usually contains a 0.5 molar concentration of NaHSO₃ and Na₂SO₄ each, which represents the suppressed solubility limits of both in solution together. All the NaHSO₃ is converted to Na₂SO₃ in the reaction tank with a very favorable reaction rate. The further conversion of Na₂SO₃ to NaOH is limited to 0.36 moles/l converted (or 0.14 moles/l residual) for an initial Na₂SO₃ concentration of 0.5 molar (5). About 72% of the SO₂ is absorbed by the NaOH in the absorber return liquor, while 28% of the SO₂ reacts with the residual Na₂SO₃. Since such a high percentage of the NaHSO₃ is regenerated to NaOH in the reaction tank, the liquor flows are lower than in the dilute mode, although pump power is not a large operating cost item.

The Na₂SO₄ is regenerated at the very low amount of 0.06 moles/1 and is observed as forming at the rate of 0.00153% SO₂/10 scf-%O₂ in pounds of Na₂SO₄ per pound of SO₂ in the absorber. This represents about 8% of the SO₂ absorbed at an oxygen content in the flue gas of 4% by volume. The absorber bleed must be sufficient to allow enough regeneration to handle the rate of production in the absorber. The removal of CaSO₂ is accomplished in the reactor clarifier as before.

Process advantages include:

- 1. Scale buildup in the absorber and mist eliminator is obviated.
- 2. Excellent lime utilization is noted.
- 3. Good particulate removal is accomplished.
- 4. Limestone can be used as the reagent in this mode, while the equilibrium concentration in the dilute mode are so low the use of limestone is precluded.

Process disadvantages are:

- Large quantities of CaSO₃ are produced with its inherent water pollution potential.
- 2. Large quantities of material movement in and out of the plant area interfere with operations.

Sodium Sulfite/Bisulfite Process

The sodium sulfite/bisulfite cycling system is remarkably simple in concept. The process flow diagram appears in Figure 13, and the chemistry follows accordingly.




Figure 13. Sodium sulfite/bisulfite SO_2 removal system.

Absorber
$$Na_2SO_3 + SO_2 + H_2O \rightarrow 2NaHSO_3$$

 $Na_2CO_3 + 2SO_2 + H_2O \rightarrow 2NaHSO_3 + CO_2$ (make up soda ash)
 $2Na_2SO_3 + O_2 \rightarrow 2Na_2SO_4$
Evaporator $2NaHSO_3 \rightarrow Na_2SO_3 + SO_2 + H_2O$
 $Na_2SO_3 + SO_2 \rightarrow Na_2S_2O_3 + O_2$

Of course, the primary reaction for SO₂ removal is the absorption by Na₂SO₃ to produce NaHSO₃, which is, in turn, regenerated in the evaporator crystalizer. The SO₂ is driven off in the evaporator at some 210F and a partial pressure of 0.27 nsca (0.39 psia), and the evaporator is specified to operate at about 8.3 nsca (12 psia). Water is condensed out of the evaporator off-gases to attain a 92% rich SO₂ stream.

The production rate of Na_2SO_4 in the absorber is again equal to 0.00153% $SO_2/10$ scf- $\%O_2$ in terms of pounds of Na_2SO_4 formed per pound SO_2 absorbed. This production rate must be purged from the system, since it cannot be regenerated in the evaporator. The concentration of Na_2SO_3 in the absorber return liquor was fixed at 0.8 moles/1, while the Na_2SO_4 concentration was allowed to ride up to 1.0 mole/1 in order to minimize the absorber bleed purge. A small low temperature (40F) crystalizer is used to treat the absorber bleed purge, the result being the selective crystalization of Na_2SO_3 and Na_2SO_4 and a reduced sodium loss to the system. The removal of Na_2SO_3 and chloride buildup in the system is accomplished by a 1 gpm direct purge to the salt cake dryer. Both purges amount to about 4 gpm.

Process advantages are:

- 1. Scale buildup in absorber and mist eliminator is eliminated.
- 2. Sulfur and salt cake products are saleable.
- Absorber operation can be decoupled from the balance of the SO₂ system.
- 4. Minimal movement of material in and out of plant area.
- 5. No disposal or water pollution problem exists with gypsum.
- Operating costs are reduced.

The disadvantage is that the system may be somewhat more complex to operate than some other systems.

Activated Char Adsorption System

The process flow diagram for this system is available in Figure 14, and the chemistry for the adsorption of SO_2 by activated char is as follows:

Adsorber
$$C + 2SO_2 + O_2 + 2H_2O \rightarrow 2H_2SO_4 + C$$

Regenerator $C + 2H_2SO_4 \rightarrow 2SO_2 + CO_2 + H_2O$

The SO₂ is adsorbed as H₂SO₄ in the porous cavities of the char, which chemically reacts with the carbon in the char on being heated to 649C (1,200F) during regeneration in the sand heater. This inevitably leads to an enlargement of the char pours and a corresponding reduction in physical strength. A stream 50% (by volume) rich in SO₂ is off-gassed in the regenerator for ultimate reduction to elemental sulfur in the sulfur reduction plant. After regeneration, the char is water-

cooled to 200F for re-entry into the absorber.

Operating experience with sulfur reduction by coal at the pilot plant level has not been successful to date (6), so operating costs for a conventional Claus plant were applied to this system for comparison. The char circulation rate around the system has been observed to range from 4 to 7 kg-char/kg-SO₂ (8-16 lb-char/lb-SO₂), with the more representative rate being 6 kg-char/kg-SO₂ (13 lb-char/lb-SO₂) as plotted (6). Since the activated char system has not been operated with all components simultaneously for a long enough period to establish char attrition rates, estimates were made to bound the area of probable consumption. The chemical losses are easily calculated to be 7 kg/min (16 lb/min) for the regenerator chemical reaction. Char abrasion losses are estimated from operating experience with thermal catalytic crackers (7) where alumina balls are lost at a rate of 0.6% of the circulation This defines the lower limit of char abrasion loss. Unfortunately, char is not as strong as alumina where a tensile strength ratio of 15, alumina to char, is easily shown. If char loss due to abrasion is linear with tensile strength, the char attrition could be 9% of the circulation. This higher char loss estimate is believed to be conservative since the estimate makes no attempt to consider the further weakening caused by increased porosity due to regeneration cycles.

The activated char system is also reported to have the capability of removing NO from the exhaust gas, which is also an oxidation-reduction reaction with an additional chemical loss to the system.

System advantages are:

- 1. Saleable sulfur product.
- Somewhat smaller amount of material movement in and out of the plant area.




Figure 14. Activated char SO_2 removal system.

3. Requirement for stack gas reheat eliminated.

System disadvantages include:

- 1. Extreme risk in operating costs without conclusive char attrition experience.
- 2. Low reliability and high maintenance of solids handling equipment.
- 3. Potential safety hazards in handling hot char ranging from 93C to 649C (200F to 1,200F).

SUMMARY

The process operating parameters of each candidate can be compared in Table 1. Both dilute acid and dilute double alkali have high absorber bleed rates, which will be manifested in larger process vessels and relatively high capital cost, but will have the more attractive filter cake product (CaSO₄ rather than CaSO₃). All processes except the sodium sulfite/bisulfite and activated char systems involve large quantities of material movement in and out of the plant area, both in the form of lime or limestone (209 tons/day) and calcium salt products (300 tons/day). The only process utilizing significant quantities of process steam is the sodium sulfite/bisulfite system. The only processes with an attractive marketable product are the sodium sulfite and activated char processes.

Operating costs are tabulated in Table 2 and plotted as a function of fuel sulfur content in Figure 15. Operating costs for four of the processes are bunched together in the narrow band shown in Figure 15, to the extent that they are undistinguishable in cost. Limestone is somewhat higher and the sodium sulfite/bisulfite process is somewhat lower. The sodium sulfite systems could be reduced an additional 0.25 mills/kWh at 1% sulfur in the fuel if the evaporator were to be sized to run at off-peak electrical demand periods (which makes it look even more attractive). The extremely high risk in the activated char system is indicated by the estimated range in operating costs because of uncertainty in char attrition. Operating costs can be converted from mills/kWh to \$/MBtu by simply multiplying the numbers in Table 2 by 0.1.

The governing laws for scaling process flows and power consumption are embodied in Equations 1 through 14. Careful examination and the combining of these relationships demonstrate that all flows and pump power scale linearly with fuel sulfur content and steam generator capacity. Fan power, on the other hand, is only a function of unit capacity. Operating costs follow similar rules. This analysis forms the basis for the scaling laws outlined in Tables 1 and 2.




Figure 15. Comparative operating costs for candidate \mathbf{SO}_2 removal systems.

REFERENCES

- 1. J. M. Slaminski. "Steam-electric unit operating parameters in relation to the emission of particulate matter, sulfur dioxide, and nitrogen oxides," 1972 American Institute of Chemical Engineers Symposium Series, Apr 1972.
- 2. J. M. Slaminski and M. H. Hooper. "Design criteria and field test data for high performance electrostatic precipitators," Air Pollution Control Association/Pacific Northwest International Section Annual Conference, Seattle, Wash., 28 Nov 1973.
- 3. Environmental Protection Agency. Series EPA-600/2-76-1366: Proceedings: Symposium on flue gas desulfurization, volumes I and II. Washington, D.C., May 1976.
- 4. Chiyoda International Corporation. Interim report on Chiyoda thoroughbred 101 coal application plant at Gulf Power's Scholz Plant, by R. B. Dakan et al. Seattle, Wash.
- 5. Environmental Protection Agency. EPA-R2-72-186: Regeneration chemistry of sodium-based double-alkali scrubbing process, by D. C. Draemel. Office of Research and Monitoring, Research Triangle Park, N.C., 1973.
- 6. W. L. Nelson. Petroleum refinery engineering, 4th ed., New York, N.Y. McGraw-Hill, 1958.
- 7. Foster Wheeler Energy Corporation. FW-BF Gulf Power Demonstration Unit Interim Results, by J. J. Strum et al. Livingston, N.J.

ACKNOWLEDGMENT

The author wishes to acknowledge the technical efforts of Mr. Dale W. Christian, currently associated with the Public Service Company of New Mexico, Albuquerque, N.M., for the development of background information and analyses used in preparing this report.

NOMENCLATURE

C _o	Operating Cost (\$/yr; mills/kWh)
Cpg	Exhaust Gas Specific Heat (Cal/g-°C; Btu/lb-°F)
đ	Inside Pipe Diameter (m; ft)
F _M	Liquor Flow Rate Margin Over Nominal Design
FRG	Fraction of Absorber Product Regenerated
FRP	Fraction of Reagent R Forming Product P
F _S	Fuel Sulfur Content
FSS	Fraction of Suspended Solids in Slurry
FURP	Utilization of Reagent R Forming Product P
f	Pipe Friction Factor
G	Steam-Electric Unit Generation Capacity (kW)
80	Gravitational Constant (M/s ² ; ft/s ²)
H	Absorber or Vessel Overall Height (m; ft)
нну	Fuel Higher Heating Value (kJ/kg; Btu/lb)
HR _N	Steam-Electric Unit Net Heat Rate (kJ/kWh; Btu/kWh)
h _w	Make-Up Water Enthalpy (kJ/kg; Btu/lb-dry gas)
h _{w1}	Water Vapor Enthalpy at Prescrubber Inlet (kJ/kg; Btu/lb)
h _{w2}	Water Vapor Enthalpy at Absorber Exist (kJ/kg; Btu/lb)
KA	Sum of Individual Pipe Fitting Loss Coefficients
L	Piping System Overall Length (m; ft)
L _c	Steam-Electric Unit Capacity Factor (Energy Generated/Capacity X Period)
m _w	Mass Addition of Make-Up Water Per Unit Mass of Dry Gas
m _{w1}	Mass Fraction of Water Vapor at Prescrubber Inlet (kg/kg; lb/lb-dry gas)
m _{w2}	Mass Fraction of Water Vapor at Absorber Exit (kg/kg; lb/lb-dry gas)
MWp	Molecular Weight of Product P (kg/mole; lb/mole)
MWR	Molecular Weight of Reagent R (kg/mole; lb/mole)
MW _{SO₂}	Sulfur Dioxide Molecular Weight (kg/mole; lb/mole)

NOMENCLATURE continued

```
P
           Number of Chemical Products From Reactions With SO,
P.
           Pump or Fan Power Requirements (kW; hp)
R
           Number of Reagents Reacting With SO,
SR
           Solubility of Reagent R (kg/l; lb/gal)
           Exhaust Gas Temperature at Prescrubber Inlet (°C; °F)
T<sub>1</sub>
           Exhaust Gas Temperature at Absorber Exit (°C; °F)
т,
           Number of Hours Per Year
t
U
           Unit Cost of Any Consumable ($/unit)
           Exhaust Gas Volumetric Flow Rate (acmm; acfm)
           Liquor Velocity (°C; °F)
           Flow Rate of Any Consumable (kg/hr; lb/hr)
           Fuel Flow Rate (kg/hr; lb/hr)
           Liquor Flow Rate (lpm; gpm)
           Product Mass Flow Rate (kg/min; lb/min)
           Reagent Mass Flow Rate (kg/min; lb/min)
           Sulfur Dioxide Mass Flow Rate (kg/min; lb/min)
X<sub>p</sub> ΔP<sub>cv</sub>
           Product Concentration in Liquor (kg/l; lb/gal)
           Control Valve Pressure Drop at Nominal Liquor Flow (nsc; psi)
ΔPg
           Exhaust Gas Pressure Loss (nsc; psi)
\Delta P_{T}
           Liquor Pressure Loss Through Piping System (nsc; psi)
\Delta P_{sn}
           Liquor Spray Nozzle or Distribution Header Pressure Loss
           (nsc; psi)
           Fan Efficiency
\eta_{\mathbf{F}}
           Adiabatic Humidification Efficiency
η<sub>H</sub>
           Pump Efficiency
η<sub>p</sub>
           Reagent Chemical Reaction Stoichiometric Coefficient (moles)
^{\nu}R
           Product Chemical Reaction Stoichiometric Coefficient (moles)
^{\nu}_{P}
           Sulfur Dioxide Chemical Reaction Stoichiometric Coefficient
^{\nu}so<sub>2</sub>
            (moles)
           Liquor Density (kg/M<sup>3</sup>; lb/ft<sup>3</sup>)
\rho_{L}
           Density of Water (kg/l; lb/gal)
Pw
```

ABBREVIATIONS

acmm actual cubic meters per minute
acfm actual cubic feet per minute

C Celsius
kJ kilojoule
kWh kilowatt hour

Btu British thermal unit

F Fahrenheit

Nsca Newtons per square centimeter absolute

psia pound per square inch absolute

molar moles per liter

MW megawatt kg kilogram min minute

1b/min pound per minute

lbm/hr pound-minute per hour

gpm grams per minute kg/hr kilogram per hour

MBtu mega-British thermal unit

in. vwc inches of vertical water column

cm vwc centimeter of vertical water column

kW/cm vwc kilowatt per centimeter of vertical water column

hp/in. vwc horsepower per inch of vertical water column

psi pounds per square inch

lpm liters per meter

Nsc Newtons per square centimeter

kW kilowatt

hp/psi horsepower per pound per square inch kW/psi kilowatt per pound per square inch

m/s meter per second fps feet per second

ABBREVIATIONS continued

m meter
ft foot
yr year
hr hour

moles/l moles per liter

scf seconds per cubic foot
vwc vertical water column

DISTRIBUTION LIST

AF ENVIRON. HEALTH LAB McClellan AFB CA

AFB (AFIT/LD), Wright-Patterson OH; ABG/DEE (F. Nethers), Goodfellow AFB TX; AFCEC/XR, Tyndall FL; AUL/LSE 63-465, Maxwell AL; CESCH, Wright-Patterson; HQ Tactical Air Cmd (R. E. Fisher), Langley AFB VA; MAC/DET (Col. P. Thompson) Scott, IL; SAMSO/MNNF, Norton AFB CA; Stinfo Library, Offutt NE AAP NAVORDSTA IND HD DET PW ENGRNG DIV, McAlester, OK; NAVORDSTA IND HD DET, NAT RES

MGR (Forester) McAlester OK

ARMY BMDSC-RE (H. McClellan) Huntsville AL; DAEN-CWE-M (LT C D Binning), Washington DC; DAEN-FEU, Washington DC; DAEN-FEU-E (J. Ronan). Washington DC; DAEN-MCE-D Washington DC; ERADCOM Tech Supp Dir. (DELSD-L) Ft. Monmouth, NJ; Natick Laboratories (Kwoh Hu) Natick MA; Tech. Ref. Div., Fort Huachuca, AZ

ARMY - CERL Library, Champaign IL

ARMY COASTAL ENGR RSCH CEN Fort Belvoir VA

ARMY CORPS OF ENGINEERS MRD-Eng. Div., Omaha NE; Seattle Dist. Library, Seattle WA

ARMY DARCOM AMCPM-CS (J. Carr), Alexandria VA

ARMY ENG DIV HNDED-CS, Huntsville AL; Hnded-Sr, Huntsville, AL

ARMY ENG WATERWAYS EXP STA Library, Vicksburg MS

ARMY ENGR DIST. Library, Portland OR

ARMY ENVIRON. HYGIENE AGCY Dir. Environ. Qual, Edgewood Arsenal MD; Water Qual Div (Doner), Aberdeen Prov Ground, MD

ARMY MATERIALS & MECHANICS RESEARCH CENTER Dr. Lenoe, Watertown MA

ARMY MISSILE R&D CMD Redstone Arsenal AL Sci. Info. Cen (Documents)

ASO PWD (ENS J.A. Jenkins), Philadelphia, PA

ASST SECRETARY OF THE NAVY Spec. Assist Energy (P. Waterman), Washington DC

BUMED Code 41-1 (CDR Nichols) Wash, DC

BUREAU OF RECLAMATION Code 1512 (C. Selander) Denver CO

MCB ENS S.D. Keisling, Quantico VA

CINCLANT Civil Engr. Supp. Plans. Ofr Norfolk, VA

CINCPAC Fac Engrng Div (J44) Makalapa, HI

CNAVRES Code 13 (Dir. Facilities) New Orleans, LA

CNM Code MAT-08T3, Washington, DC; NMAT 08T246 (Dieterle) Wash, DC

CNO Code NOP-964, Washington DC; Code OP 323, Washington DC; Code OP 987 Washington DC; Code OP-413 Wash, DC; Code OPNAV 09B24 (H); OP987J (J. Boosman), Pentagon

COMFLEACT, OKINAWA PWO, Kadena, Okinawa

COMNAVMARIANAS Code N4, Guam

COMOCEANSYSPAC SCE, Pearl Harbor HI

COMSUBDEVGRUONE Operations Offr, San Diego, CA

DEFENSE CIVIL PREPAREDNESS AGENCY J.O. Buchanan, Washington DC

DEFENSE DOCUMENTATION CTR Alexandria, VA

DEPT OF ENERGY L. Divone, Wash DC

DOD Staff Spec. Chem. Tech. Washington DC

DOE Dr. Cohen; Dr. Vanderryn, Washington, DC; F.F. Parry, Washington DC; FCM (WE UTT) Washington DC; P. Jordan Washington, DC

DTNSRDC Code 284 (A. Rufolo), Annapolis MD

DTNSRDC Code 4111 (R. Gierich), Bethesda MD

DTNSRDC Code 4121 (R. Rivers), Annapolis, MD

DTNSRDC Code 42, Bethesda MD

DTNSRDC Code 522 (Library), Annapolis MD

ENERGY R&D ADMIN. INEL Tech. Lib. (Reports Section), Idaho Falls ID; Liffick, Richmond, WA

ENVIRONMENTAL PROTECTION AGENCY MD-18(P. Halpin), Research Triangle Park NC; Reg. VIII, 8M-ASL, Denver CO; Reg. X Lib. (M/S 541), Seattle WA

FLTCOMBATTRACENLANT PWO, Virginia Bch VA

FMFLANT CEC Offr, Norfolk VA

FAA Civil Aeromedical Institute, Oklahoma City, OK

GSA Office of Const. Mgmt (M. Whitley). Washington DC

HEDSUPPACT PWO, Taipei, Taiwan

HQ UNC/USFK (Crompton), Korea

KWAJALEIN MISRAN BMDSC-RKL-C

MARINE CORPS BASE Camp Pendleton CA 92055; Code 43-260, Camp Lejeune NC; M & R Division, Camp Lejeune NC; PWO, Camp S. D. Butler, Kawasaki Japan

MARINE CORPS HQS Code LFF-2, Washington DC

MCAS Facil. Engr. Div. Cherry Point NC; CO, Kaneohe Bay HI; Code PWE, Kaneohe Bay HI; Code S4, Quantico VA; J. Taylor, Iwakuni Japan; PWD, Dir. Maint. Control Div., Iwakuni Japan; PWO Kaneohe Bay HI; PWO Utilities (Paro), Iwakuni, Japan; PWO, Yuma AZ; SCE, Futema Japan; UTC Dupalo, Iwakoni, Japan

MCDEC NSAP REP, Quantico VA MCLSBPAC B520, Barstow CA; PWO, Barstow CA

MCRD PWO, San Diego Ca

MILITARY SEALIFT COMMAND Washington DC

NAD Engr. Dir. Hawthorne, NV

NAF PWO Sigonella Sicily; PWO, Atsugi Japan

NAS Asst C/S CE Corpus Christi, TX; CO, Guantanamo Bay Cuba; Code 114, Alameda CA; Code 183 (Fac. Plan BR MGR); Code 187, Jacksonville FL; Code 18700, Brunswick ME; Code 18U (ENS P.J. Hickey), Corpus Christi TX; Code 6234 (G. Trask), Point Mugu CA; Code 70, Atlanta, Marietta GA; Code 8E, Patuxent Riv., MD; Dir. Util. Div., Bermuda; ENS Buchholz, Pensacola, FL; Lakehurst, NJ; Lead. Chief. Petty Offr. PW/Self Help Div., Beeville TX; PW (J. Maguire), Corpus Christi TX; PWD (M.B. Trewitt), Dallas TX; PWD Maint. Cont. Dir., Fallon NV; PWD Maint. Div., New Orleans, Belle Chasse LA; PWD, Maintenance Control Dir., Bermuda; PWD, Willow Grove PA; PWO (M. Elliott), Los Alamitos CA; PWO Belle Chasse, LA; PWO Chase Field Beeville, TX; PWO Key West FL; PWO Whiting Fld, Milton FL; PWO, Dallas TX; PWO, Glenview IL; PWO, Kingsville TX; PWO, Millington TN; PWO, Miramar, San Diego CA; PWO,, Moffett Field CA; SCE Lant Fleet Norfolk, VA; SCE, Norfolk, VA; SCE, Barbers Point HI; Security Offr, Alameda CA

NATL RESEARCH COUNCIL Naval Studies Board, Washington DC

NATNAVMEDCEN PWO Bethesda, MD

NATPARACHUTETESTRAN PW Engr, El Centro CA

NAVACT PWO, London UK

NAVAEROSPREGMEDCEN SCE, Pensacola FL

NAVAL FACILITY PWO, Barbados; PWO, Brawdy Wales UK; PWO, Cape Hatteras, Buxton NC; PWO, Centerville Bch, Ferndale CA; PWO, Guam

NAVAVIONICFAC PWD Deputy Dir. D/701, Indianapolis, IN

NAVCOASTSYSLAB CO, Panama City FL; Code 423 (D. Good), Panama City FL; Code 715 (J. Mittleman) Panama City, FL; Code 715 (J. Quirk) Panama City, FL; Library Panama City, FL

NAVCOMMAREAMSTRSTA Code W-602, Honolulu, Wahiawa HI; PWO, Norfolk VA; PWO, Wahiawa HI; SCE Unit 1 Naples Italy

NAVCOMMSTA CO (61E) Puerto Rico; CO, San Miguel, R.P.; Code 401 Nea Makri, Greece; PWO, Adak AK; PWO, Exmouth, Australia; PWO, Fort Amador Canal Zone

NAVCOMMUNIT Cutler/E. Machias ME (PW Gen. For.)

NAVCONSTRACEN CO (CDR C.L. Neugent), Port Hueneme, CA

NAVEDTRAPRODEVCEN Tech. Library

NAVENVIRHLTHCEN CO, Cincinnati, OH

NAVEODFAC Code 605, Indian Head MD

NAVFAC PWO, Lewes DE

NAVFACENGCOM Code 043 Alexandria, VA; Code 044 Alexandria, VA; Code 0451 Alexandria, VA; Code 0454B Alexandria, VA; Code 04B3 Alexandria, VA; Code 04B5 Alexandria, VA; Code 081B Alexandria, VA; Code 101 Alexandria, VA; Code 1023 (M. Carr) Alexandria, VA; Code 1023 (T. D. Stevens), Alexandria VA; Code 1023 (T. Stevens) Alexandria, VA; Code 104 Alexandria, VA; Code 2014 (Mr. Taam), Pearl Harbor HI; Morrison Yap, Caroline Is.; PW Brewer; PC-22 (E. Spencer) Alexandria, VA; PL-2 Ponce P.R. Alexandria, VA

NAVFACENGCOM - CHES DIV. Code 101 Wash, DC; Code 102, (Wildman), Wash, DC; Code 402 (R. Morony) Wash, DC; Code 403 (H. DeVoe) Wash, DC; Code 405 Wash, DC; Code FPO-1 (C. Bodey) Wash, DC; Code FPO-1 (Ottsen) Wash, DC; Code FPO-1SP (Dr. Lewis) Wash, DC; Code FPO-1P12 (Mr. Scola), Washington DC

NAVFACENGCOM - LANT DIV.; Code 111, Norfolk, VA; Eur. BR Deputy Dir, Naples Italy; LANTDIV (E.J. Peltier) Alexandria, VA; RDT&ELO 09P2, Norfolk VA

NAVFACENGCOM - NORTH DIV. (Boretsky) Philadelphia, PA; AROICC, Brooklyn NY; CO; Code 09P (LCDR A.J. Stewart); Code 1028, RDT&ELO, Philadelphia PA; Code 111 (Castranovo) Philadelphia, PA; Code 114 (A. Rhoads); Design Div. (R. Masino), Philadelphia PA; ROICC, Contracts, Crane IN

NAVFACENGCOM - PAC DIV. Code 09DG (Donovan), Pearl Harbor, HI; Code 402, RDT&E, Pearl Harbor HI; Commander, Pearl Harbor, HI

NAVFACENGCOM - SOUTH DIV. Code 90, RDT&ELO, Charleston SC; Dir., New Orleans LA

NAVFACENGCOM - WEST DIV. 102; 112; AROICC, Contracts, Twentynine Palms CA; Code 04B; Code 114C. San Diego CA; O9P/20; RDT&ELO Code 2011 San Bruno, CA

NAVFACENGCOM CONTRACT AROICC, Point Mugu CA; AROICC, Quantico, VA; Code 05, TRIDENT, Bremerton WA; Code 09E, TRIDENT, Bremerton WA; Dir, Eng. Div., Exmouth, Australia; Eng Div dir, Southwest Pac, Manila, PI; OICC (Knowlton), Kaneohe, HI; OICC, Southwest Pac, Manila, PI; OICC/ROICC, Balboa Canal Zone; ROICC (LCDR J.G. Leech), Subic Bay, R.P.; ROICC AF Guam; ROICC LANT DIV., Norfolk VA; ROICC Off Point Mugu, CA; ROICC, Keflavik, Iceland; ROICC, Pacific, San Bruno CA

NAVFORCARIB Commander (N42), Puerto Rico

NAVHOSP LT R. Elsbernd, Puerto Rico

NAVNUPWRU MUSE DET Code NPU-30 Port Hueneme, CA; Code NPU80 (ENS W. Morrison), Port Hueneme CA

NAVOCEANO Code 1600 Bay St. Louis, MS; Code 3408 (J. Kravitz) Bay St. Louis

NAVOCEANSYSCEN Code 3400 San Diego CA; Code 409 (D. G. Moore), San Diego CA; Code 52 (H. Talkington) San Diego CA; Code 5224 (R.Jones) San Diego CA; Code 6565 (Tech. Lib.), San Diego CA; Code 6700, San Diego, CA; Code 7511 (PWO) San Diego, CA; Code 811 San Diego, CA; Research Lib., San Diego CA; SCE (Code 6600), San Diego CA

NAVORDFAC Security Offr, Sasebo, Japan

NAVORDSTA PWO, Louisville KY

NAVPETOFF Code 30, Alexandria VA

NAVPETRES Director, Washington DC

NAVPGSCOL Code 1424 Monterey, CA; E. Thornton, Monterey CA; LCDR K.C. Kelley Monterey CA

NAVPHIBASE CO, ACB 2 Norfolk, VA; Code S3T, Norfolk VA

NAVRADRECFAC PWO, Kami Seya Japan

NAVREGMEDCEN Chief of Police, Camp Pendleton CA; PWO Newport RI; PWO Portsmouth, VA; SCE (D. Kaye); SCE (LCDR B. E. Thurston), San Diego CA; SCE, Camp Pendleton CA; SCE, Guam

NAVREGMEDCLINIC F. Hertlein III, Pearl Harbor HI

NAVSCOLCECOFF C35 Port Hueneme, CA; C44A (R. Chittenden), Port Hueneme CA; CO, Code C44A Port Hueneme, CA

NAVSEASYSCOM Code 0325, Program Mgr, Washington, DC; Code OOC (LT R. MacDougal), Washington DC; Code SEA OOC Washington, DC

NAVSEC Code 6034 (Library), Washington DC

NAVSECGRUACT PWO, Edzell Scotland; PWO, Puerto Rico; PWO, Torri Sta, Okinawa

NAVSHIPREPFAC SCE Subic Bay

NAVSHIPYD; CO Marine Barracks, Norfolk, Portsmouth VA; Code 202.4, Long Beach CA; Code 202.5 (Library) Puget Sound, Bremerton WA; Code 380, (Woodroff) Norfolk, Portsmouth, VA; Code 400, Puget Sound; Code 400.03 Long Beach, CA; Code 404 (LT J. Riccio), Norfolk, Portsmouth VA; Code 410, Mare Is., Vallejo CA; Code 440 Portsmouth NH; Code 440, Norfolk; Code 440, Puget Sound, Bremerton WA; Code 440.4, Charleston SC; Code 450, Charleston SC; Code 453 (Util. Supr), Vallejo CA; L.D. Vivian; Library, Portsmouth NH; PWD (Code 400), Philadelphia PA; PWD (LT N.B. Hall), Long Beach CA; PWO, Mare Is.; PWO, Puget Sound; SCE, Pearl Harbor HI; Tech Library, Vallejo, CA

NAVSTA CO Naval Station, Mayport FL; CO Roosevelt Roads P.R. Puerto Rico; Engr. Dir., Rota Spain; Maint. Cont. Div., Guantanamo Bay Cuba; Maint. Div. Dir/Code 531, Rodman Canal Zone; PWD (LT W.H. Rigby), Guantanamo Bay Cuba; PWO Midway Island; PWO, Keflavik Iceland; PWO, Mayport FL; ROICC, Rota Spain; SCE, Guam; SCE, San Diego CA; SCE, Subic Bay, R.P.; Utilities Engr Off. (LTJG A.S. Ritchie). Rota Spain

NAVSUBASE ENS S. Dove, Groton, CT; LTJG D.W. Peck, Groton, CT; SCE, Pearl Harbor HI

NAVSUPPACT CO, Brooklyn NY; CO, Seattle WA; Code 4, 12 Marine Corps Dist, Treasure Is., San Francisco CA; Code 413, Seattle WA; LTJG McGarrah, Vallejo CA; Plan/Engr Div., Naples Italy

NAVSURFWPNCEN PWO, White Oak, Silver Spring, MD

NAVTECHTRACEN SCE, Pensacola FL

NAVTORPSTA Keyport, WA

NAVWPNCEN Code 2636 (W. Bonner), China Lake CA; PWO (Code 26), China Lake CA; ROICC (Code 702), China

NAVWPNEVALFAC Technical Library, Albuquerque NM

NAVWPNSTA (Clebak) Colts Neck, NJ; Code 092, Colts Neck NJ; Code 092A (C. Fredericks) Seal Beach CA; ENS G.A. Lowry, Fallbrook CA; Maint. Control Dir., Yorktown VA; PW Office (Code 09C1) Yorktown, VA; PWO, Seal Beach CA; Qual. Engr. Ctr., Fallbrook CA

NAVWPNSUPPCEN Code 09 (Boennighausen) Crane IN

NCBU 405 OIC, San Diego, CA

NORDA Code 410 Bay St Louis, MS

NCBC CEL (CAPT N. W. Petersen), Port Hueneme, CA; CEL AOIC Port Hueneme CA; Code 10 Davisville, RI; Code 155, Port Hueneme CA; Code 156, Port Hueneme, CA; Code 25111 Port Hueneme, CA; Code 400, Gulfport MS; NESO Code 251 P.R. Winter Port Hueneme, CA; PW Engrg, Gulfport MS; PWO (Code 80) Port Hueneme, CA; PWO, Davisville RI

NCBU 411 OIC, Norfolk VA

NCR 20, Commander

NCSO BAHRAIN Security Offr, Bahrain

NMCB 133 (ENST.W. Nielsen); 5, Operations Dept.; Forty, CO; THREE, Operations Off.

NOAA Libraries Div. - D823, Silver Spring, MD

NORDA Code 440 (Ocean Rsch, Off) Bay St. Louis, MS

NRL Code 8400 (J. Walsh), Washington DC; Code 8441 (R.A. Skop), Washington DC

NSC CO, Biomedical Rsch Lab, Oakland CA; Code 54.1 (Wynne), Norfolk VA

NSD SCE, Subic Bay, R.P.

NTC Code 54 (ENS P. G. Jackel), Orlando FL; Commander Orlando, FL; OICC, CBU-401, Great Lakes IL; SCE Great Lakes, IL

NAVOCEANSYSCEN Hawaii Lab (D. Moore), Hawaii

NUSC Code 131 New London, CT; Code EA123 (R.S. Munn), New London CT; Code SB 331 (Brown), Newport RI; Code TA131 (G. De la Cruz), New London CT

OCEANAV Mangmt Info Div., Arlington VA

OCEANSYSLANT LT A.R. Giancola, Norfolk VA

OFFICE SECRETARY OF DEFENSE OASD (I&L) Pentagon (T. Casberg), Washington DC

ONR; BROFF, CO Boston MA; Code 221, Arlington VA; Code 481, Arlington VA; Code 700F Arlington VA; Dr. A. Laufer, Pasadena CA

PACMISRANFAC CO, Kekaha HI

PMTC Code 4253-3, Point Mugu, CA; Pat. Counsel, Point Mugu CA

PWC ENS J.E. Surash, Pearl Harbor HI; ACE Office (LTJG St. Germain) Norfolk VA; CO Norfolk, VA; CO, Great Lakes IL; Code 116 (LTJG. A. Eckhart) Great Lakes, IL; Code 120, Oakland CA; Code 120C (Library) San Diego, CA; Code 128, Guam; Code 200, Great Lakes IL; Code 200, Oakland CA; Code 220 Oakland, CA; Code 220.1, Norfolk VA; Code 30C (Boettcher) San Diego, CA; Code 40 (C. Kolton) Pensacola, FL; Code 42B (R. Pascua), Pearl Harbor HI; Code 505A (H. Wheeler); Code 680, San Diego CA; OIC CBU-405, San Diego CA; XO Oakland, CA

SPCC Code 122B, Mechanicsburg, PA; PWO (Code 120) Mechanicsburg PA

TVA Smelser, Knoxville, Tenn.

U.S. MERCHANT MARINE ACADEMY Kings Point, NY (Reprint Custodian)

US GEOLOGICAL SURVEY Off. Marine Geology, Piteleki, Reston VA

USAF Maj. Riffel, Rumstein, Germany

USAF REGIONAL HOSPITAL Fairchild AFB, WA

USCG (G-ECV) Washington Dc; (G-ECV/61) (Burkhart) Washington, DC; G-EOE-4/61 (T. Dowd), Washington DC USCG ACADEMY LT N. Stramandi, New London CT

USCG R&D CENTER CO Groton, CT; D. Motherway, Groton CT; LTJG R. Dair, Groton CT; Tech. Dir. Groton, CT

USNA Ch. Mech. Engr. Dept Annapolis MD; Energy-Environ Study Grp, Annapolis, MD; Engr. Div. (C. Wu) Annapolis MD; Environ. Prot. R&D Prog. (J. Williams), Annapolis MD; Ocean Sys. Eng Dept (Dr. Monney) Annapolis, MD; PWD Engr. Div. (C. Bradford) Annapolis MD; PWO Annapolis MD

AMERICAN UNIVERSITY Washington DC (M. Norton)

ARIZONA State Energy Programs Off., Phoenix AZ

AVALON MUNICIPAL HOSPITAL Avalon, CA

BONNEVILLE POWER ADMIN Portland OR (Energy Consrv. Off., D. Davey)

CALIFORNIA INSTITUTE OF TECHNOLOGY Pasadena CA (Keck Ref. Rm)

CALIFORNIA STATE UNIVERSITY LONG BEACH, CA (CHELAPATI)

COLUMBIA-PRESBYTERIAN MED. CENTER New York, NY

CORNELL UNIVERSITY Ithaca NY (Serials Dept, Engr Lib.)

DAMES & MOORE LIBRARY LOS ANGELES, CA

DUKE UNIV MEDICAL CENTER B. Muga, Durham NC

FLORIDA ATLANTIC UNIVERSITY BOCA RATON, FL (MC ALLISTER)

FLORIDA ATLANTIC UNIVERSITY Boca Raton FL (W. Tessin)

FLORIDA TECHNOLOGICAL UNIVERSITY ORLANDO, FL (HARTMAN)

FOREST INST. FOR OCEAN & MOUNTAIN Carson City NV (Studies - Library)

FUEL & ENERGY OFFICE CHARLESTON, WV

HAWAII STATE DEPT OF PLAN. & ECON DEV. Honolulu HI (Tech Info Ctr)

ILLINOIS STATE GEO. SURVEY Urbana IL

INDIANA ENERGY OFFICE Energy Group, Indianapolis, IN

VIRGINIA INST. OF MARINE SCI. Gloucester Point VA (Library)

KEENE STATE COLLEGE Keene NH (Cunningham)

LEHIGH UNIVERSITY BETHLEHEM, PA (MARINE GEOTECHNICAL LAB., RICHARDS); Bethlehem PA (Linderman Lib. No.30, Flecksteiner)

LIBRARY OF CONGRESS WASHINGTON, DC (SCIENCES & TECH DIV)

LOUISIANA DIV NATURAL RESOURCES & ENERGY Dept. of Conservation, Baton Rouge LA

LOW COUNTRY REG. PLAN. COUNCIL YEMASSEE, SC (BAGGS)

MAINE MARITIME ACADEMY (Wyman) Castine ME

MAINE OFFICE OF ENERGY RESOURCES Augusta, ME

MICHIGAN TECHNOLOGICAL UNIVERSITY Houghton, MI (Haas)

MISSOURI ENERGY AGENCY Jefferson City MO

MIT Cambridge MA; Cambridge MA (Rm 10-500, Tech. Reports, Engr. Lib.); Cambridge, MA (Harleman)

MONTANA ENERGY OFFICE Helena, MT

NATL ACADEMY OF ENG. ALEXANDRIA, VA (SEARLE, JR.)

NEW MEXICO SOLAR ENERGY INST. Dr. Zwibel Las Cruces NM

NY CITY COMMUNITY COLLEGE BROOKLYN, NY (LIBRARY)

NYS ENERGY OFFICE Library, Albany NY

OREGON Salem OR (State Office of Allocation & Conserv.)

PENNSYLVANIA STATE UNIVERSITY State College PA (Applied Rsch Lab)

POLLUTION ABATEMENT ASSOC. Graham, Corte Madera, CA

PURDUE UNIVERSITY Lafayette, IN (CE Engr. Lib)

CONNECTICUT Hartford CT (Dept of Plan. & Energy Policy)

SCRIPPS INSTITUTE OF OCEANOGRAPHY LA JOLLA, CA (ADAMS); San Diego, CA (Marina Phy. Lab. Spiess)

SEATTLE U Prof Schwaegler Seattle WA

SOUTHWEST RSCH INST J. Maison, San Antonio TX; R. DeHart, San Antonio TX

STANFORD UNIVERSITY Engr Lib, Stanford CA

STATE HOUSE AUGUSTA, ME (MAINE STATE FUEL ALLOC & CONSERV. OFF.)

STATE UNIV. OF NEW YORK Fort Schuyler, NY (Longobardi)

TEXAS A&M UNIVERSITY COLLEGE STATION, TX (CE DEPT); College Station TX (CE Dept. Herbich)

UNIVERSITY OF CALIFORNIA BERKELEY, CA (CE DEPT, GERWICK); BERKELEY, CA (OFF. BUS. AND

FINANCE, SAUNDERS); Berkeley CA (E. Pearson); LIVERMORE, CA (LAWRENCE LIVERMORE LAB, TOKARZ); La Jolla CA (Acq. Dept, Lib. C-075A); Off-Campus Facs & Energy Conserv., Davis, CA; Off-Campus

Facs & Energy Conserv., Davis, CA; SAN DIEGO, CA, LA JOLLA, CA (SEROCKI); Vice President, Berkeley, CA

UNIVERSITY OF DELAWARE Newark, DE (Dept of Civil Engineering, Chesson)

UNIVERSITY OF HAWAII Dr Chiu Honolulu, HI; HONOLULU, HI (SCIENCE AND TECH. DIV.)

UNIVERSITY OF ILLINOIS Metz Ref Rm, Urbana IL; URBANA, IL (LIBRARY); URBANA, IL (NEWARK)

UNIVERSITY OF KANSAS Kansas Geological Survey, Lawrence KS

UNIVERSITY OF MASSACHUSETTS (Heronemus), Amherst MA CE Dept

UNIVERSITY OF MICHIGAN Ann Arbor MI (Richart)

UNIVERSITY OF NEBRASKA-LINCOLN Lincoln, NE (Ross Ice Shelf Proj.)

UNIVERSITY OF RHODE ISLAND KINGSTON, RI (PAZIS); KINGSTON, RI (SUSSMAN); Narragansett RI (Pell Marine Sci. Lib.)

UNIVERSITY OF TEXAS Inst. Marine Sci (Library), Port Arkansas TX

UNIVERSITY OF TEXAS AT AUSTIN AUSTIN, TX (THOMPSON)

UNIVERSITY OF WASHINGTON Dept of Civil Engr (Dr. Mattock), Seattle WA; SEATTLE, WA (APPLIED PHYSICS LAB); SEATTLE, WA (OCEAN ENG RSCH LAB, GRAY); Seattle WA (E. Linger); Seattle, WA Transportation, Construction & Geom. Div

UNIVERSITY OF WISCONSIN Milwaukee WI (Ctr of Great Lakes Studies)

URS RESEARCH CO. LIBRARY SAN MATEO, CA

VENTURA COUNTY ENVIRON RESOURCE AGENCY Ventura, CA (Melvin)

VERMONT STATE ENERGY OFFICE MONTEPELIER, VT (DIRECTOR)

ALBANY FELT CO ALBANY, NY (EICK)

AMSCO Dr. R. McCoy, Erie, PA

ARCAIR CO. D. Young, Lancaster OH

ARVID GRANT OLYMPIA, WA

ATLANTIC RICHFIELD CO. DALLAS, TX (SMITH)

USNA Sys. Engr. Dept (R. McCoy) Annapolis, MD

BECHTEL CORP. SAN FRANCISCO, CA (PHELPS)

BELGIUM HAECON, N.V., Gent

BRITISH EMBASSY Sci. & Tech. Dept. (J. McAuley), Washington DC

BROWN & ROOT Houston TX (D. Ward)

CANADA Adrian, Anderson & Assoc., Winnipeg; Nova Scotia Rsch Found, Corp. Dartmouth, Nova Scotia;

Surveyor, Nenninger & Chenevert Inc., Montreal; Warnock Hersey Prof. Srv Ltd, La Sale, Quebec

CAYWOOD, NOPP, WARD, AIA Sacramento, CA

CHEMED CORP Lake Zurich IL (Dearborn Chem. Div.Lib.)

CHEVRON OIL FIELD RESEARCH CO. LA HABRA, CA (BROOKS)

COLUMBIA GULF TRANSMISSION CO. HOUSTON, TX (ENG. LIB.)

CONCRETE TECHNOLOGY CORP. TACOMA, WA (ANDERSON)

DESIGN SERVICES Beck, Ventura, CA

DILLINGHAM PRECAST F. McHale, Honolulu HI

DIXIE DIVING CENTER Decatur, GA

DRAVO CORP Pittsburgh PA (Giannino); Pittsburgh PA (Wright)

DURLACH, O'NEAL, JENKINS & ASSOC. Columbia SC

EVALUATION ASSOC. INC KING OF PRUSSIA, PA (FEDELE)

EXXON PRODUCTION RESEARCH CO Houston TX (A. Butler Jr)

FORD, BACON & DAVIS, INC. New York (Library)

GENERAL DYNAMICS Elec. Boat Div., Environ. Engr (H. Wallman), Groton CT

GLIDDEN CO. STRONGSVILLE, OH (RSCH LIB)

GLOBAL MARINE DEVELOPMENT NEWPORT BEACH, CA (HOLLETT)

GRUMMAN AEROSPACE CORP. Bethpage NY (Tech. Info. Ctr)

HUGHES AIRCRAFT Culver City CA (Tech. Doc. Ctr)

MAKAI OCEAN ENGRNG INC. Kailua, HI

JAMES CO. R. Girdley, Orlando FL

LAMONT-DOHERTY GEOLOGICAL OBSERV. Palisades NY (Selwyn)

LOCKHEED MISSILES & SPACE CO. INC. L. Trimble, Sunnyvale CA; Mgr Naval Arch & Mar Eng Sunnyvale,

CA; Sunnyvale CA (Rynewicz); Sunnyvale, CA (Phillips)

MARATHON OIL CO Houston TX (C. Seay)

MATRECON Oakland, CA (Haxo)

MCDONNEL AIRCRAFT CO. Dept 501 (R.H. Fayman), St Louis MO

MEDERMOTT & CO. Diving Division, Harvey, LA

MIDLAND-ROSS CORP. TOLEDO, OH (RINKER)

NEWPORT NEWS SHIPBLDG & DRYDOCK CO. Newport News VA (Tech. Lib.)

NORWAY I. Foss, Oslo; Norwegian Tech Univ (Brandtzaeg), Trondheim

OCEAN DATA SYSTEMS, INC. SAN DIEGO, CA (SNODGRASS)

OCEAN RESOURCE ENG. INC. HOUSTON, TX (ANDERSON)

PACIFIC MARINE TECHNOLOGY LONG BEACH, CA (WAGNER)

PORTLAND CEMENT ASSOC. Skokie IL (Rsch & Dev Lab, Lib.)

RAYMOND INTERNATIONAL INC. E Colle Soil Tech Dept, Pennsauken, NJ

RIVERSIDE CEMENT CO Riverside CA (W. Smith)

SAFETY SERVICES, INC. A. Patton, Providence RI

SANDIA LABORATORIES Albuquerque, NM (Vortman); Library Div., Livermore CA

SCHUPACK ASSOC SO. NORWALK, CT (SCHUPACK)

SEAFOOD LABORATORY MOREHEAD CITY, NC (LIBRARY)

SEATECH CORP. MIAMI, FL (PERONI)

SHELL DEVELOPMENT CO. HOUSTON,, TX (TELES); Houston TX (C. Sellars Jr.)

SHELL OIL CO. Houston TX (R. de Castongrene)

SWEDEN VBB (Library), Stockholm

TEXTRON INC BUFFALO, NY (RESEARCH CENTER LIB.)

THE AM. WATERWAYS OPERATIONS, INC. Arlington, VA (Schuster)

TIDEWATER CONSTR. CO Norfolk VA (Fowler)

TRW SYSTEMS CLEVELAND, OH (ENG. LIB.); REDONDO BEACH, CA (DAI)

UNITED KINGDOM Cement & Concrete Assoc (G. Somerville) Wexham Springs, Slou; D. Lee, London; D. New.

G. Maunsell & Partners, London; J. Derrington, London; Library, Bristol; Taylor, Woodrow Constr (014P).

Southall, Middlesex; Taylor, Woodrow Constr (Stubbs), Southall, Middlesex; Univ. of Bristol (R. Morgan), Bristol

UNITED TECHNOLOGIES Windsor Locks CT (Hamilton Std Div., Library)

WESTINGHOUSE ELECTRIC CORP. Annapolis MD (Oceanic Div Lib, Bryan); Library, Pittsburgh PA WEYERHAEUSER CO. LONGVIEW, WA (TECH CTR LIB)

WISS, JANNEY, ELSTNER, & ASSOC Northbrook, IL (J. Hanson) WM CLAPP LABS - BATTELLE DUXBURY, MA (LIBRARY)

WOODWARD-CLYDE CONSULTANTS PLYMOUTH MEETING PA (CROSS, III)

ADAMS, CAPT (RET) Irvine, CA
BRAHTZ La Jolla, CA
BRYANT ROSE Johnson Div. UOP, Glendora CA
BULLOCK La Canada
KRUZIC, T.P. Silver Spring, MD
CAPT MURPHY Sunnyvale, CA
GREG PAGE EUGENE, OR
R.F. BESIER Old Saybrook CT
R.Q. PALMER Kaitua, HI
T.W. MERMEL Washington DC
CEC Donofrio, John L., LT